




# Micromegas for sampling calorimetry

M. Chefdeville pour le groupe LC du LAPP  
Conseil scientifique IN2P3, 30/01/2014

- x Micromegas & gaseous calorimetry*
- x Group expertise & resources*
- x Achievements*
- x Future*

# Micromegas & gaseous calorimetry

Low multiplication factor – Narrow avalanche – Fast charge collection → Space charge field  $\sim 0$   
→ Signal are proportional to the energy deposited in the gas ↔ *linear response*



Mesh lies on pillars (1% dead zone) → uniform E-field → *Small constant term & easy calibration*

High rate capability of tens of MHz/cm<sup>2</sup> → *Barrel/endcap/forward region-compatible*

Simple gas (e.g. Ar/CO<sub>2</sub>) & low voltages (500 V, 40 kV/cm) → *No ageing*



Gas gain dependence on P/T/V well known → *Response stable with time*

# Semi-digital hadron calorimetry

Micromegas suitable for ECAL & HCAL. In the case of Particle-Flow calorimetry:

- ✗ Alternative to Si for W-ECAL but with larger Molière radius & worse energy resolution;
- ✗ *Candidate for a Fe-DHCAL (ILC)* and W-DHCAL (CLIC).

Expected response & resolution to pions of a HCAL with 1-bit & 2-bit readout (Geant4)



The response of a DHCAL is saturated with consequences on the energy resolution.

But off-line compensation techniques can be used to correct for it, e.g. 2-bit readout.

# Group expertise

## Prototyping

Large area Micromegas with embedded ASICs

Spark protection with resistive coatings

Micro-electronics (MICROROC ASIC with Omega)

## Detector optimisation (simulation)

Analogue/digital performance

Compensation algorithms

Geometry optimisation (SDHCAL & SiD barrel)

## Data acquisition for SDHCAL

Design of front-end board (DIF)





Firmware of all readout boards

## Software

Acquisition for Micromegas (Labview)

Reco & analysis of SDHCAL (C++ framework)

Physics studies Z' & SUSY particles @ CLIC



DCC : Data Concentrator




# Collaborations, resources & chronology

Strong implication in CALICE (SDHCAL), RD51 (large MPGD), CLIC (det. & phys.)



Collaborators: IN2P3 groups, Irfu, Athens NTUA, Weizmann institute

Funds: IN2P3, ANR (SDHCAL & SPLAM), AAP





2006-2009

*Proof-of-principle*




2009-2012

*Large area (SDHCAL)*



2012-2013

*Spark protection (SPLAM)*



# Micromegas prototype of 1x1 m<sup>2</sup>




ASIC (MICROROC) with noise of  $\sim 6500 e^-$  RMS

Threshold of 1 fC (S/N $\sim$ 25) with a dispersion of 0.2 fC RMS

Active Sensor Units (24 ASIC) with flexible interconnects + spark protections


(+ calibration inputs, analogue readout & T sensor)

Modular mechanical design based on 6 ASU: thickness <1 cm, 2% dead zones







# Highlights of testbeam results (characterisation)

Shower profile - 150 GeV pions - 370 V






*Excellent uniformity*

*Low noise (1 Hz/ASIC in SDHCAL)*



*Rate capable at shower max (150 GeV pions)*


*Efficiency > 95%*



*Multiplicity ~ 1*

# Highlights of testbeam results (calorimetry 1/2)

1. we measured the number of hits behind various Fe-absorber thickness...



*Pions (SPS) 20-150 GeV*


SDHCAL (46 RPC + 4 Micromegas)

→ Shower start ID



*Electrons (DESY) 1-5 GeV*

1 Micromegas + N absorbers

No shower start ID but little fluctuations





2. and determine the shower longitudinal profile in a SDHCAL at various energies...





# Highlights of testbeam results (calorimetry 2/2)

3. by integration of the profile, we obtain the response of a virtual Micromegas SDHCAL...



4. and start testing Monte Carlo (so far for pions only)


→ Lots of (shower) physics with a few layers!

# Highlights of simulation work (1/2)


Our model of Micromegas SDHCAL fits well the measured pion response

It is used to investigate the [energy resolution of a SDHCAL to single pions](#) (before studying jets)


*Raw DHCAL response needs corrections for leaks & saturation*



*Rear leakage (Fe)*  
*Number of layer*



*Saturation (Fe)*  
*Pad size*



*Saturation*  
*Absorber Fe-W*



# Highlights of simulation work (2/2)

## Compensation

= equalisation of response to EM and H part of hadron showers improves linearity & resolution

→ EM energy is concentrated in a small volume (Molière radius) → geometric saturation

→ In a (S)DHCAL, it can be tagged with hit density or with multi-threshold readout





# Resistive Micromegas (1/2)

## Improvements of existing large prototypes

Avoid discharges (measured probability =  $10^{-6}$  / showering pion /  $m^2$ ) with resistive layers

Simplify PCB by removing current-limiting diodes




Challenge 1: do not change efficiency/multiplicity → specific R-strip patterns



# Resistive Micromegas (2/2)

Challenge 2: Maintain rate capability as high as possible



## Rate scan


5 GeV  $e^-$  beam  
Collim.  $2 \times 2 \text{ cm}^2$

Thr0 = 0.5 MIP  
Thr1 = 5 MIP  
Thr2 = 15 MIP

Rate effects in resistive prototypes seen but remain small

Analysis on-going to understand & model the underlying mechanisms

# Future plans (and publication)



Two R&D phases completed: large area Micromegas (SDHCAL) & resistive Micromegas (SPLAM)

→ Next is : calorimeter prototype with large area resistive Micromegas

*ANR proposal called **Sampling Calorimetry with Resistive Anode Micromegas (SCREAM)***

## ANR = 0

Validate resistive large area Micromegas

→ Enlarge PCB size to 48x48 cm<sup>2</sup>

→ Modify 1x1 m<sup>2</sup> chamber design (4 ASU)

## ANR = 1

Validate Micromegas calorimetry

→ 50 layers of 48x48 cm<sup>2</sup>

→ Full characterisation completed in 2017

# Conclusions

✗All tests carried out so far prove that **Micromegas is a very good choice for a SDHCAL**

We expect that a Micromegas calorimeter would out-perform other gaseous technologies

✗Good and improving **understanding of the SDHCAL possibilities**

Sustained analysis effort of RPC-SDHCAL testbeam data & Geant4 simulation

✗LAPP group gained a **strong expertise in R&D for calorimetry**

✗Fruitful **interaction with IN2P3 groups** (ASIC, DAQ, software)

✗With/without ANR support: well defined road map till a possible positive decision of Japan